



Jim Doyle, Governor
Mary P. Burke, Secretary

July 23, 2007

SNYDER INDUSTRIES, INCORPORATED
CRAIG S WYLER
4700 FREMONT
PO BOX 4583
LINCOLN NE 68504

Re: Description: SEWAGE TANKS, POLYETHYLENE
Manufacturer: SNYDER INDUSTRIES, INCORPORATED
Product Name: NU CON SEPT - SEPTIC
Model Number(s): 1250 GAL (Part No. 508XXX)
(L.L. = 48", L.L./GAL = 11"/250; 15"/3251; 19"/463; 22"/2519; 26"/675; 30"/760; 34"/844;
37"/948; 41"/1052; 45"/1152; 48"/1250, 24" MAX. DEPTH OF BURY; 599 G.P.D. WHEN
USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20070319

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on 07/6/2002 under product file number 20020267. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020267.

A copy of a successful water tightness test report for the product approved under this product file number in the regarding block must be submitted to this office prior to this product being sold for installation in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov